


MAY 2021



**2020**



**Annual  
Drinking Water  
Quality Report**

CITY OF  
*Sheridan*



— WYOMING —

## EXCELLENCE IN DRINKING WATER

We are very pleased to provide you with our Annual Drinking Water Quality Report, also known as the Consumer Confidence Report. This report is a snapshot of last year's water quality and is designed to provide comprehensive information about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies, such as the Environmental Protection Agency. We are committed to providing you with accurate information regarding exceptional water and services that we have delivered to you over the course of this past year. We believe informed customers are our best allies. Our constant goal is

to provide you with a safe and dependable supply of drinking water. Your water meets or exceeds the requirements of the Federal Safe Drinking Water Act (SDWA).

All of the water we provide to you comes from creeks, streams, lakes, and reservoirs in the Big Horn National Forest's Big Goose drainage. Sheri-



The diversion dam at our Intake Facility in Big Goose Canyon.

dan's Water Intake facility is located at the mouth of Big Goose Canyon, upstream of many contaminants, which helps reduce possible contamination.

### Source Water Assessment

Wyoming Department of Environmental Quality (DEQ) has conducted a source water assessment for the City of Sheridan. This report shows where our water comes from and potential sources of contamination which may affect our water supply. The report and map can be reviewed at City Hall or on our website at:

<http://www.sheridanwy.gov/government/utilities/water>

## SPECIAL PRECAUTIONS

Some individuals may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as those undergoing chemotherapy, organ transplant recipients, individuals with HIV/AIDS or other immune system disorders, and also the elderly and infants, can be particularly at risk. These individuals should seek advice about their drinking water from their health care providers. The U.S. Environmental Protection Agency (EPA)/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800)426-4791. In addition, you may visit the following websites for more information:


<https://www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-hotline>

<https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulations#Microorganisms>

## OUR TREATMENT PROCESS

Your water is treated in a "treatment train" (a series of sequential processes) that includes coagulation, flocculation, sedimentation, filtration, and disinfection.

- *Coagulation* removes dirt and other particles suspended in the source water by adding chemicals (coagulants) to form tiny sticky particles called "floc," which attract the dirt particles.
- *Flocculation* (the formation of larger flocs from smaller flocs) is achieved using gentle, constant mixing. The heavy particles settle naturally out of the water in a sedimentation basin.
- The clear water then moves to the *filtration* process where the water passes through sand, gravel and anthracite filters that remove even smaller particles.
- After filtration, *disinfection* adds a small amount of chlorine to kill bacteria and other microorganisms that may be in the water before



The surface water treatment process.

the water is stored and distributed to homes and businesses in the community.

Recent Water Treatment Plant upgrades have improved plant performance, increased efficiencies, and have ensured compliance with EPA's LT2 (Cryptosporidium) Rule.

## LEAD IN DRINKING WATER



The City of Sheridan and Sheridan Area Water Supply (SAWS) care about the health of families in our community and want to help limit exposure to lead in drinking water. We take steps to control water chemistry at our water treatment plants to help prevent lead from leaching into drinking water, and we test for levels of lead and copper in the City's water distribution system as required by federal and state regulatory laws. There are no known sources of lead in our water distribution system.

Lead in drinking water occurs primarily from materials and components associated with property owner's service lines and household plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. The City of Sheridan is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. We encourage families to take precautions to ensure they are not exposed to lead at the tap. Families can take steps to reduce their risk by:

- After a period of stagnation, flush your tap for 30 seconds to 2 minutes before using water for drinking or cooking in order to retrieve fresh water that is coming from the main distribution line (Consider using the water to flush toilets or water plants in order to minimize waste).
- Purchase a point-of-use treatment device certified to remove lead and properly maintain the device.
- Avoid consuming water from the hot water tap, where lead, if present, is more likely to appear.

If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the EPA Safe Drinking Water Hotline (800) 426-4791, or website at: <http://www.epa.gov/safewater/lead>

## WATER QUALITY DATA TABLES

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table on the following page lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were

found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of

drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered

vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In the table, you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below.

### Important Drinking Water Definitions & Abbreviations

**MCLG- Maximum Contaminant Level Goal.** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL- Maximum Contaminant Level.** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**TT- Treatment Technique.** A required process intended to reduce the level of a contaminant in drinking water.

**AL- Action Level.** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Variances and Exemptions-** State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**MRDLG- Maximum Residual Disinfection Level Goal.** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MRDL- Maximum Residual Disinfectant Level.** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary

for control of microbial contaminants.

**MNR- Monitored Not Regulated.**

**MRL- Minimum Reporting Level.** The smallest measured concentration of a substance that can be reliably measured by using a given analytical method.

**MPL- Maximum Permissible Level.** The highest level of a contaminant that is allowed in drinking water.

**ppm- parts per million or milligrams per Liter (mg/L)**

**ppb- parts per billion or micrograms per Liter (µg/L)**

**NTU- Nephelometric Turbidity Units.** A measure of the cloudiness of the water, e.g. crystal clear water vs. water that looks like chocolate milk.

**Rfc- Reference Concentration.** An estimate of a continuous inhalation exposure to the human population that is likely to be without an appreciable risk of deleterious effects during a lifetime.

**Positive samples/month- Number of samples taken per month that were found to be positive.**

**N/A- Not applicable.**

**ND- Not detected.**

**NR- Not required.**

**Total Trihalomethanes (TTHMs)** Some people who drink trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

# WATER QUALITY DATA TABLES

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation?	Typical Source
				Low	High			
<b>Disinfectants and Disinfectant By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (Cl <sub>2</sub> ) (ppm)	4	4	1.55	.59	2.51	2020	No	Water Additive used to control microbes
<sup>1</sup> Haloacetic Acids (HAA5) (ppb)	N/A	60	42.8	27	72.4	2020	Yes	By-product of drinking water chlorination
Total Trihalomethanes (TTHM) (ppb)	N/A	80	43.4	26	68.5	2020	No	By-product of drinking water disinfection
Total Organic Carbon (% removal)	N/A	TT	36.1	23.5	52.2	2020	No	Naturally present in the environment
<b>Inorganic Contaminants</b>								
Sodium (ppm)	Not est.	Not est.	11.5	10.0	13.0	2020	No	Erosion of natural deposits, leaching
<b>Microbial Contaminants</b>								
Turbidity (NTU)	N/A	1	.03	.01	.14	2020	No	Soil runoff
Turbidity has no health effects, however, it can interfere with proper disinfection. 100% of the samples were below the TT value of .3 NTU. A TT violation occurs when <95% of the samples are below .15 NTU. Any measurement in excess of 1 is a violation unless otherwise approved by the EPA.								
Total Coliform (positive samples/month)	0	1 positive sample/month	0	N/A	N/A	2020	No	Naturally present in the environment
E.Coli bacteria or Fecal Coliform	0	1 positive sample/month	0	N/A	N/A	2020	No	Human or animal fecal waste
Contaminants	MCLG	AL	Your Water	Sample Date	# of Samples exceeding AL	Exceeds?	Typical Source	
<b>Inorganic Chemicals</b>								
Fluoride (ppm)	4	4	0.0	2020	N/A *Fluoride feed was removed from our water in 2019	No	Erosion of natural deposits; naturally occurring or treatment chemical additive that promotes dental health	
Lead (ppb)	0	15	0	2020	0	No	Corrosion of household plumbing systems	
Copper (ppm)	1.3	1.3	.09	2020	0	No	Erosion of natural deposits; corrosion of household plumbing systems	

1. A violation occurred with a process error at a 3rd party lab.

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Monitoring Requirements Not Met for City of Sheridan

Our water system received a violation over the 2020 compliance period. Results of regular monitoring are indicators of whether or not your drinking water meets health standards. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

#### What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant we did not properly test for during the compliance period, how often we are supposed to sample and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been	When samples were taken
<u>Haloacetic Acids</u>	4 sample sites, taken 4 times per year	4	July 2020	July 2020

#### What happened? What is being done?

We are required to collect four Haloacetic Acid samples per quarter from our system on a very strict monitoring schedule. We collected our 4 samples on time, per our schedule and sent them to a third party laboratory for analysis. Due to a laboratory error, one sample taken last July failed a Quality Control check, invalidating the analysis resulting in a sample rejection. Due to ongoing laboratory concerns, we have since switched to an alternate laboratory for future disinfection by-product samples. This is a “Tier 3” violation (does not have a direct impact on human health). Had this been a “Tier 1 violation, consumers would have been notified immediately .

For more information, please contact Tom Manolis at (307) 674-8532 Or at the City of Sheridan, PO Box 848 Sheridan WY 82801.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by City of Sheridan.

Public Water System ID#: WY5600052.

Date distributed: June 2021.

## ARE THERE CONTAMINANTS IN MY DRINKING WATER?

All drinking water, including bottled water, may be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by contacting the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800)426-4791) or on-line at: <http://www.epa.gov/sdwa>



Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases,

radioactive material, and can pick up substances resulting from the presence of animals or other sources, such as human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in the water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for human health.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from industrial or domestic wastewater discharge, oil and gas production, mining, or farming.



**Contaminants are naturally occurring in both the air and water. Through our treatment process, harmful contaminants are eliminated or controlled.**

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, can be naturally occurring or the result of oil and gas pro-

We're on the web!

<http://www.sheridanwy.gov/government/utilities/water>

## CITY OF SHERIDAN

55 Grinnell Plaza  
Sheridan, WY 82801  
(307) 674-6483

For more information, please contact:

### Water Supply & Treatment Division

Tom Manolis  
*Water Supply & Treatment Superintendent*  
6 Soldier Creek Rd.  
Sheridan, WY 82801  
(307) 674-8532  
[tmanolis@sheridanwy.gov](mailto:tmanolis@sheridanwy.gov)

Report a problem  
Request service  
Send a suggestion  
Send a comment

Connect Sheridan  
Mobile App

Puts City Hall at  
your fingertips!



*Be observant. Notice and report any suspicious activity around our water sources.*

## WATER CONSERVATION TIPS

### Indoors

- Fix a leak.
- Turn off running water when not in use (ex. when brushing your teeth).
- Opt for a quick shower instead of a bath.
- Install water efficient fixtures and appliances.
- Run the dishwasher only when completely full or wash dishes in a sink filled with water.
- Run the clothes washer only when completely full.
- Keep a pitcher of water in the fridge instead of letting the water run until cold.
- Thaw food in the fridge overnight instead of under running water.
- Skip the garbage disposal.

### Outdoors

- Create a water-smart landscape and water accordingly.
- Wash the car with a bucket or at a commercial place that recycles used water.
- Water smarter— it's best to water in the early morning or evenings. Make sure your sprinkler system is calibrated correctly.
- Let your grass grow. Over-watering grass leads to shallow roots, more weeds, and less drought resistance.
- Sweep driveways, sidewalks, and steps instead of hosing them off.
- Water plants at the roots, not the leaves.
- Use the right tool, the right way! A standard garden hose and nozzle leads to water loss due to mist, runoff, or

evaporation. Try a soaker hose instead.

- Take the kids to cool off at the pool, park, or in the mountains. Mother nature offers plenty of natural cooling resources— all you have to do is find the time to indulge in them.

### During a Drought

- Follow the rules.
- Cut back on watering— water conservation is more important than a bright green lawn during a drought.
- Check for leaks.
- Go the extra mile. Collect and use rainwater or repurpose used water.

## How can I get involved?

This report is meant to inform you about the quality of water and services we deliver to you each and every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. If you have questions about the quality of your drinking water or this report, please contact Tom Manolis, Water Superintendent at the Water Supply and Treatment Division at (307) 674-8532, between 7 a.m. and 3:30 p.m., or the Utilities Administration Office at City Hall, (307) 674-6483, between 8 a.m. and 5 p.m. Sheridan City Council meets the 1st and 3rd Mondays of each month at 7:00 p.m. in City Hall Council Chambers. For more information on Sheridan Area Water Supply Joint Powers Board (SAWSJPB) meetings, please call (307) 675-2930.



For more information, please visit:

**EPA WaterSense**  
<https://www.epa.gov/watersense>



To view this report online, please visit:

[www.sheridanwy.gov/government/utilities/water](http://www.sheridanwy.gov/government/utilities/water)